DATASHEET - FAZ-C50/1



Miniature circuit breaker (MCB), 50A, 1p, C-Char, AC

AU

Powering Business Worldwide*

Part no. FAZ-C50/1 Catalog No. 278566 Alternate Catalog FAZ-C50/1

No.

EL-Nummer 0001695159

(Norway)

Similar to illustration

Delivery program

Delivery program			
Basic function			Miniature circuit-breakers
Number of poles			1 pole
Tripping characteristic			C
Application			Switchgear for industrial and advanced commercial applications
Rated current	In	Α	50
Rated switching capacity acc. to IEC/EN 60947-2	I _{cu}	kA	15
Product range			FAZ

Technical data

Electrical

Standards			IEC/EN 60947-2 IEC/EN 60898
Rated operational voltage	U _e	V	
	U _e	V AC	240/415
		V DC	60 (per pole)
Rated voltage according to UL	Un	V AC	277
Rated switching capacity acc. to IEC/EN 60947-2	I _{cu}	kA	15
Breaking capacity according to UL		kA	5 (UL1077)
Operational switching capacity		kA	7.5
Characteristic			B, C, D, K, S, Z
Max. back-up fuse		A gL/gG	125
Selectivity Class			3
lifespan			
Lifespan	Operations		> 10000
Direction of incoming supply			as required
Mechanical			
Standard front dimension		mm	45
Enclosure height		mm	80
Mounting width per pole		mm	17.5
Mounting			IEC/EN 60715 top-hat rail
Degree of Protection			IP20, IP40 (when fitted)
Terminals top and bottom			Twin-purpose terminals
Terminal protection			Finger and back-of-hand proof to BGV A2
Terminal capacities		mm ²	
		mm^2	1 x 25
		mm ²	2 x 10
Thickness of busbar material		mm	0.8 2
Mounting position			As required

Design verification as per IEC/EN 61439

Technical data for design verification	ı
--	---

10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.2 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.8 Dees not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.9.1 Internal electrical circuits and connections 10.9.1 Internal electrical circuits and connections 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.9.1 Temperature rise 10.9.2 Power-frequency electric strength 10.9.1 Internal electrical circuits and connections 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9 Insulation properties 10.9 Insulation p				
Equipment heat dissipation, current-dependent Pris W 4.5 Static heat dissipation, non-current-dependent Pris W 0.0 Dereating ambient temperature min. Coperating ambient temperature min. Coperating ambient temperature min. Coperating ambient temperature max. Co 75 ECEN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Front financing and parts 10.2.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric internal electric internal electric strength 10.2.3 Heart financing and impact 10.3.1 Heart financing and impact 10.3.2 Heart financing and impact 10.3.2 Heart financing and impact 10.3.3 Legislation of thermal stability of enclosures 10.3.4 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.4.3 Resistance to ultra-violet (UV) radiation 10.5.2 Hinag 10.2.5 Lifting 10.3.5 Lifting 10.4 Resistance of ultra-violet (UV) radiation 10.5 Degree of protection of ASSEMBLIES 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Incorporation of switching devices and components 10.9 Insulation properties 10.9 Insulation properties 10.1 Short-circuit rating 10.1 Temperature rise 10.1 Short-circuit rating 10.1 Temperature rise 10.1 Short-circuit rating 10.2 Short-circuit rating 10.3 Short-circuit rating 10.4 Short-circuit rating 10.5 Short-circuit rating 10.6 Short-circuit rating 10.7 Short-circuit	Rated operational current for specified heat dissipation	In	Α	50
Static heat dissipation, non-current-dependent Pes W 0 Destating ambient temperature min. °C - 40 Operating ambient temperature max. °C - 40 Certain gambient temperature max. °C - 75 ECEN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3 Lyerification of resistance of insulating materials to normal heat and fir due to internal electrical effects 10.2.3 Lyerification of resistance of insulating materials to abnormal heat and fir due to internal electrical effects 10.2.5 Ething 10.2.6 Mechanical impact 10.2.7 Internal electrical circuits and connections 10.3 Degree of protection of ASSEMBLIES 10.3 Learness and creapage distances 10.3 Degree of protection of ASSEMBLIES 10.3 Recognition of switching devices and components 10.3 Internal electrical circuits and connections 10.3 Incorporation of switching devices and connections 10.3 Incorporation of switching devices and connections 10.3 Internal electrical circuits and connections 10.4 Resting of enclosures made of insulating material 10.5 Interpreture rise 10.6 Recapporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Interpreture rise 10.9 Resting a penal builder's responsibility. 10.9 Internal electrical circuits and connections 10.1 Internal electrical circuits and connections 10.2 Internal electrical circuits and connections 10.3 Internal electrical circuits and connections 10.4 Resting of enclosures made of insulating material 10.5 Recognition of the evite	Heat dissipation per pole, current-dependent	P _{vid}	W	0
Heat dissipation capacity Operating ambient temperature min. Operating ambient temperature max. FOR 140 Comparison ambient temperature max. FOR 1438 design verification 10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3 Verification of thermal stability of enclosures 10.2.3 Verification of thermal stability of enclosures 10.2.3 Verification of thermal stability of enclosures 10.2.3 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.4 Serification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.5 Unitary 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Deepere of protection of ASSEMBLIES 10.3 Segree of protection against electric shock 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Insulation properties 10.9 Prover-frequency electric strength 10.9 Insulation properties 10.9 Insulati	Equipment heat dissipation, current-dependent	P _{vid}	W	4.5
Deparating ambient temperature min. Deparating ambient temperature max. CFC 75 Innear, per +1 °C, results in a 0.5% reduction of current carrying capacity EC/EN 61439 design verification 10.2 Strength of materials and parts 10.2.2 Cornosion resistance 10.2.3 Verification of resistance of insulating materials to normal heat 10.2.3 Verification of resistance of insulating materials to abnormal heat 10.2.3 Verification of resistance of insulating materials to abnormal heat 10.2.3 Verification of resistance of insulating materials to abnormal heat 10.2.6 Resistance to ultra-violet (UV) radiation 10.2.6 Resistance to ultra-violet (UV) radiation 10.2.7 Inscriptions 10.2.8 Mechanical impact 10.2.9 Mechanical impact 10.2.9 Special of protection of ASSEMBLIES 10.2 Resistance of protection of ASSEMBLIES 10.2 Resistance of protection of ASSEMBLIES 10.2 Resistance of protection of assembly, since the entire switchgear needs to be evaluated. 10.2 Protection against electric shock 10.3 Inscription of switching devices and components 10.3 Incorporation of switching devices and components 10.3 Incorporation of switching devices and components 10.3 Inscription of switching devices and components 10.3 Inscription of switching devices and components 10.4 Temperature electrical circuits and connections 10.5 Inscription of switching devices and components 10.5 Inscription of switching devices and components 10.5 Inscription of switching devices and components 10.6 Connections for external conductors 10.7 Internal electrical circuits and connections 10.8 Legal Resistance of external conductors 10.9 Prover-frequency electric strength 10.9 Prover-frequency electric strength 10.9 Inscription 10.9 Inscription 10.9 Prover-frequency electric strength 10.9 Inscription 10.9 Inscription 10.9 Prover-frequency electric strength 10.9 Inscription 10.9 Inscription 10.9 Inscription 10.9 Inscription 10.9 Inscription 10.9 Inscription 10.9 Prover-frequency electric strength 10.9 Inscription 10.9 Inscri	Static heat dissipation, non-current-dependent	P _{vs}	W	0
C 75	Heat dissipation capacity	P _{diss}	W	0
Inear, per +1 °C, results in a 0.5% reduction of current carrying capacity EC/EN 61439 design verification	Operating ambient temperature min.		°C	-40
EC/EN 61439 design verification 10.2 Strength of materials and parts 10.2.3 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultre-violet (UV) radiation 10.2.5 Litting 10.2.6 Rechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.2.8 Degree of protection of ASSEMBLIES 10.2.9 Dees not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions 10.8 Locaraces and creepage distances 10.9 Dees not apply, since the entire switchgear needs to be evaluated. 10.5 Incorporation of switching devices and components 10.5 Incorporation of switching devices and components 10.5 Power-frequency electric strength 10.8 Connections for external conductors 10.9 Insulation properties 10.9.1 Power-frequency electric istrength 10.9.2 Power-frequency electric istrength 10.3 Impulse withstand voltage 10.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, Power-frequency electric strength 10.15 the panel builder's responsibility. 11.15 the panel builder's responsibility. 12.16 Incorporation of enclosures made of insulating material 10.17 Internal electric strength 10.18 the panel builder's responsibility. 10.29 Power-frequency electric istrength 10.3 Impulse withstand voltage 10.4 Testing of enclosures made of insulating material 10.5 Internal electric strength 10.6 Internal electric strength 10.7 Testing and electric strength 10.8 Testing of enclosures made of insulating material 10.9 Temperature rise 10.9 Power-frequency electric strength 10.9 Temperature rise 10.9 Temperature rise 10.9 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic	Operating ambient temperature max.		°C	75
10.2 Strength of materials and parts 10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLES 10.3 Degree of protection of ASSEMBLES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.9 Insulation properties 10.9 Insulation prope				linear, per +1 °C, results in a 0.5% reduction of current carrying capacity
10.2.2 Corrosion resistance 10.2.3.1 Verification of thermal stability of enclosures Meets the product standard's requirements. 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.2.7 Inscriptions Meets the product standard's requirements. 10.3.0 Begree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4.1 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.1 Shower-frequency electric strength 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9 Insulation properties 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating List the panel builder's responsibility. 11.1 Short-circuit rating List the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility List the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	IEC/EN 61439 design verification			
10.2.3.1 Verification of thermal stability of enclosures 10.2.3.2 Verification of resistance of insulating materials to normal heat 10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Electromal electric effects 10.2.5 Electromal electric effects 10.2.5 Mechanical impact 10.2.5 Mechanical impact 10.2.5 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Frotection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.1 Power-frequency electric strength 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Temperature, rise 10.17 Electromagnetic compatibility 10.18 Insulation properties 10.19 Insulation properties 10.19 Insulation properties 10.10 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.14 Mechanical function 10.15 Mechanical function 10.16 Meets the product standard's requirements. 10.17 Meets the product standard's requirements. 10.18 Meets the product standard's requirements. 10.19 Insulation properties 10.19 Insulation prop	10.2 Strength of materials and parts			
10.2.3.2 Verification of resistance of insulating materials to normal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9 Internal electric strength 10.9 Insulation properties 10	10.2.2 Corrosion resistance			Meets the product standard's requirements.
10.2.3.3 Verification of resistance of insulating materials to abnormal heat and fire due to internal electric effects 10.2.4 Resistance to ultra-violet (UV) radiation 10.2.5 Lifting 10.2.6 Mechanical impact 10.2.7 Inscriptions 10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances 10.4 Clearances and creepage distances 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9 Insulation properties 10.9.1 Temperature rise 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. In the panel builder's responsibility. Is the panel builder's responsibility. It is the panel builder's responsibility. The panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction of the switchgear must be observed.	10.2.3.1 Verification of thermal stability of enclosures			Meets the product standard's requirements.
and fire due to internal electric effects 10.24 Resistance to ultra-violet (UV) radiation 10.25 Lifting Does not apply, since the entire switchgear needs to be evaluated. 10.26 Mechanical impact Does not apply, since the entire switchgear needs to be evaluated. 10.27 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Lis the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.3.2 Verification of resistance of insulating materials to normal heat			Meets the product standard's requirements.
Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsibility. 10.10 Temperature rise Is the panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction				Meets the product standard's requirements.
10.2.6 Mechanical impact 10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.3 Impulse withstand voltage Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder is responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.4 Resistance to ultra-violet (UV) radiation			Meets the product standard's requirements.
10.2.7 Inscriptions Meets the product standard's requirements. 10.3 Degree of protection of ASSEMBLIES Does not apply, since the entire switchgear needs to be evaluated. 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock Does not apply, since the entire switchgear needs to be evaluated. 10.6 Incorporation of switching devices and components Does not apply, since the entire switchgear needs to be evaluated. 10.7 Internal electrical circuits and connections Is the panel builder's responsibility. 10.8 Connections for external conductors Is the panel builder's responsibility. 10.9 Insulation properties 10.9.2 Power-frequency electric strength Is the panel builder's responsibility. 10.9.4 Testing of enclosures made of insulating material Is the panel builder's responsibility. 10.10 Temperature rise The panel builder's responsibility. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.5 Lifting			Does not apply, since the entire switchgear needs to be evaluated.
10.3 Degree of protection of ASSEMBLIES 10.4 Clearances and creepage distances Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.2.6 Mechanical impact			Does not apply, since the entire switchgear needs to be evaluated.
Meets the product standard's requirements. 10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. In provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed.	10.2.7 Inscriptions			Meets the product standard's requirements.
10.5 Protection against electric shock 10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder's responsibility. Is the panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.3 Degree of protection of ASSEMBLIES			Does not apply, since the entire switchgear needs to be evaluated.
10.6 Incorporation of switching devices and components 10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Does not apply, since the entire switchgear needs to be evaluated. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder is responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In the device meets the requirements, provided the information in the instruction	10.4 Clearances and creepage distances			Meets the product standard's requirements.
10.7 Internal electrical circuits and connections 10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder's responsibility. Is the panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.5 Protection against electric shock			Does not apply, since the entire switchgear needs to be evaluated.
10.8 Connections for external conductors 10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function 10.14 Short-circuit for external conductors 10.15 Is the panel builder's responsibility. 10.16 Is the panel builder's responsibility. 10.17 Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.19 Mechanical function 10.19 The device meets the requirements, provided the information in the instruction	10.6 Incorporation of switching devices and components			Does not apply, since the entire switchgear needs to be evaluated.
10.9 Insulation properties 10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. The panel builder is responsibility. The specifications for the switchgear must be observed. The panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.7 Internal electrical circuits and connections			Is the panel builder's responsibility.
10.9.2 Power-frequency electric strength 10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function Is the panel builder's responsibility. Is the panel builder's responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction	10.8 Connections for external conductors			Is the panel builder's responsibility.
10.9.3 Impulse withstand voltage 10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise 10.11 Short-circuit rating 10.12 Electromagnetic compatibility 10.13 Mechanical function 10.13 Mechanical function Is the panel builder's responsibility. The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9 Insulation properties			
10.9.4 Testing of enclosures made of insulating material 10.10 Temperature rise The panel builder's responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.2 Power-frequency electric strength			Is the panel builder's responsibility.
10.10 Temperature rise The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.3 Impulse withstand voltage			Is the panel builder's responsibility.
provide heat dissipation data for the devices. 10.11 Short-circuit rating Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.9.4 Testing of enclosures made of insulating material			Is the panel builder's responsibility.
observed. 10.12 Electromagnetic compatibility Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.10 Temperature rise			
observed. 10.13 Mechanical function The device meets the requirements, provided the information in the instruction	10.11 Short-circuit rating			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:specification}$
	10.12 Electromagnetic compatibility			Is the panel builder's responsibility. The specifications for the switch gear must be observed. $\label{eq:constraint}$
	10.13 Mechanical function			

Technical data ETIM 7.0

Circuit breakers and fuses (EG000020) / Miniature circuit breaker (MCB) (EC000042)

Electric engineering, automation, process control engineering / Electrical installation, device / Miniature circuit breaker system (MCB) / Miniature circuit breaker (MCB)


Number of poles (total) Number of protected poles Rated current Rated voltage Rated voltage Rated insulation voltage Ui Rated impulse withstand voltage Uimp Rated short-circuit breaking capacity Icn EN 60898 at 230 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity	(ecl@ss10.0.1-27-14-19-01 [AAB905014])		
Number of protected poles Rated current A 50 Rated voltage V 230 Rated insulation voltage Ui Rated short-circuit breaking capacity Icn EN 60898 at 230 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icn EN 60897-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-c	Release characteristic		С
Rated current Rated voltage Rated insulation voltage Ui Rated insulation voltage Uimp Rated impulse withstand voltage Uimp Rated short-circuit breaking capacity Icn EN 60898 at 230 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Voltage type Requency Current limiting class A 50 440 440 4 10 5 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6 6	Number of poles (total)		1
Rated voltage Rated insulation voltage Ui Rated impulse withstand voltage Uimp Rated short-circuit breaking capacity Icn EN 60898 at 230 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit	Number of protected poles		1
Rated insulation voltage Ui Rated impulse withstand voltage Uimp Rated short-circuit breaking capacity Icn EN 60898 at 230 V Rated short-circuit breaking capacity Icn EN 60898 at 400 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Voltage type Frequency Current limiting class AC Current limiting class	Rated current	А	50
Rated impulse withstand voltage Uimp kV 4 Rated short-circuit breaking capacity Icn EN 60898 at 230 V kA 10 Rated short-circuit breaking capacity Icn EN 60898 at 400 V kA 10 Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V kA 15 Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V kA 15 Voltage type AC Frequency Hz 50 - 60 Current limiting class 3	Rated voltage	V	230
Rated short-circuit breaking capacity Icn EN 60898 at 230 V kA 10 Rated short-circuit breaking capacity Icn EN 60898 at 400 V kA 10 Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V kA 15 Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V kA 15 Voltage type AC Frequency Hz 50 - 60 Current limiting class 3	Rated insulation voltage Ui	V	440
Rated short-circuit breaking capacity Icn EN 60898 at 400 V kA 15 Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V kA 15 Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V kA 15 Voltage type AC Frequency Hz 50 - 60 Current limiting class 3	Rated impulse withstand voltage Uimp	kV	4
Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V kA 15 Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V kA 15 Voltage type AC Frequency Hz 50 - 60 Current limiting class 3	Rated short-circuit breaking capacity Icn EN 60898 at 230 V	kA	10
Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V Voltage type AC Frequency Hz 50 - 60 Current limiting class	Rated short-circuit breaking capacity Icn EN 60898 at 400 V	kA	10
Voltage type AC Frequency Hz 50 - 60 Current limiting class 3	Rated short-circuit breaking capacity Icu IEC 60947-2 at 230 V	kA	15
Frequency Hz 50 - 60 Current limiting class 3	Rated short-circuit breaking capacity Icu IEC 60947-2 at 400 V	kA	15
Current limiting class 3	Voltage type		AC
	Frequency	Hz	50 - 60
Suitable for flush-mounted installation No	Current limiting class		3
	Suitable for flush-mounted installation		No

Concurrently switching N-neutral		No
Over voltage category		3
Pollution degree		2
Additional equipment possible		Yes
Width in number of modular spacings		1
Built-in depth	mm	70.5
Degree of protection (IP)		IP20
Ambient temperature during operating	°C	-25 - 75
Connectable conductor cross section multi-wired	mm²	1 - 25
Connectable conductor cross section solid-core	mm²	1 - 25

Approvals


Product Standards	IEC/EN 60947-2; IEC/EN 60898; UL 1077; CSA-C22.2 No. 235; CE marking
UL File No.	E177451
UL Category Control No.	QVNU2, QVNU8
CSA File No.	204453
CSA Class No.	3215-30
North America Certification	UL recognized, CSA certified
Conditions of Acceptability	Supplementary Protector only
Suitable for	Branch Circuits; not as BCPD
Current Limiting Circuit-Breaker	No
Max. Voltage Rating	277 VAC; 48 VDC
Degree of Protection	IEC: IP20; UL/CSA Type: -

Characteristics





Let-through energy I²t According to IEC/EN 60898






6/9





Dimensions



Additional product information (links)

AWA1220-1755 Circiut-breaker

AWA1220-1755 Circiut-breaker

ftp://ftp.moeller.net/DOCUMENTATION/AWA_INSTRUCTIONS/17550701.pdf